

Ref: FOI/GS/ID 5300

Please reply to:
FOI Administrator
Trust Management
Maidstone Hospital
Hermitage Lane
Maidstone
Kent
ME16 9QQ
Email: mtw-tr.foiadmin@nhs.net

01 March 2019

Freedom of Information Act 2000

I am writing in response to your request for information made under the Freedom of Information Act 2000 in relation to Cladding.

You asked:

- 1. if any of the trust's buildings have any type of cladding on the outside*
- 2. If so, how many buildings have cladding, how tall are the buildings with cladding and what type of cladding is it*
- 3. how many of the trust's buildings are of timber frame construction*

Trust response:

1. Yes

2.

Maidstone main hospital building has a pressed steel cladding decorative facade which has no ACM and is at its highest elevation 7.8 meters

PET CT Building new build (Maidstone 2017) approximate elevation 4 meters cladding type Trespa Meteon standard panel

Tunbridge Wells Hospital at its highest elevation is 33.6 meters, cladding type is 55mm/57mm Kingspan Thermapitch TP10 – encapsulated PIR (not ACM)

3. None