

Ref: FOI/GS/ID 7515

**Please reply to:**  
FOI Administrator  
Trust Management  
Maidstone Hospital  
Hermitage Lane  
Maidstone, Kent  
ME16 9QQ  
Email: [mtw-tr.foiadmin@nhs.net](mailto:mtw-tr.foiadmin@nhs.net)  
[www.mtw.nhs.uk](http://www.mtw.nhs.uk)

05 July 2022

### **Freedom of Information Act 2000**

I am writing in response to your request for information made under the Freedom of Information Act 2000 in relation to onsite incinerator.

*You asked:*

*I would like to know if the hospital has its own onsite incinerator and if it does, is it still used / how often is it used?*

*I would also like to know how the hospital's backup generator is powered, as in, what fuel is used?*

Trust response:

Maidstone Hospital:

Onsite incinerator

Maidstone Hospital does not have an onsite incinerator

Standby generation

The generators are supplied by light fuel oil.

Tunbridge Wells Hospital:

Onsite incinerator

Tunbridge Wells Hospital does not have an onsite incinerator

Standby generation

The generators are supplied by light fuel oil.